



CITY OF KIRKLAND
123 5th Avenue
Kirkland, WA 98033
www.kirklandpermits.net

**DO NOT REMOVE
ELECTRICAL INSPECTION
CORRECTION REPORT**

INSPECTION REQUEST LINE (425) 587-3605. Request must be made prior to 7pm for next day inspection. The corrections listed below are hereby ordered and must be completed within 15 days. Refer to National Electrical Code or State Rules for Safety Standards.

OWNER / CONTRACTOR	Final	DATE	4 / 22 / 14
ADDRESS	9123 Juanita Drive UNIT 204	PERMIT NUMBER	EMF12-04377

NOT APPROVED FOR COVER NOT APPROVED FOR SERVICE

SAFETY DEFECTS NEEDING CORRECTION

1- Plug not allowed in the bath tub space - remove wiring from the box feeding this plug and the wire in this box and cover the box

**NOTIFY INSPECTION OFFICE WHEN
READY FOR REINSPECTION**

John Hosen
INSPECTOR