DO NOT REMOVE

BUILDING INSPECTION CORRECTION REPORT

CITY OF KIRKLAND
123 5th Avenue
Kirkland, WA 98033
www.kirklandpermits.net

The corrections listed below are hereby required and must be corrected prior to any further inspection requests.

DATE 10 / 20 / 14	
TYPE OF INSPECTION FRAMING	PERMIT NUMBER BSF13-06050
ADDRESS 5555 116TH AVE NE	

(1) SHEATHING REQUIRED AT (2) P1-6 INTERIOR WALLS - LAUNDY + BATH

(2) BUILD CRIPPLE WALL PER S2/6 SHEATHING & STRAPS

(3) PROVIDE CONNECTION FROM ROOF DIAPHRAM TO INTERIOR WALL PER S1/3 & OUR DISCUSSION

OK TO INSULATE

INSPECTOR MIKE MCGIVERN

When ready for reinspection, call (425) 587-3605 prior to 7 p.m. for next day inspection. Building Department Business Line: (425) 587-3600.