CITY OF KIRKLAND
123 5th Avenue
Kirkland, WA 98033
www.kirklandpermits.net

DO NOT REMOVE

ELECTRICAL INSPECTION CORRECTION REPORT

INSPECTION REQUEST LINE ~~(425) 587-3805~~ Request must be made prior to 7pm for next day inspection. The corrections listed below are hereby ordered and must be completed within **15 days.** Refer to National Electrical Code or State Rules for Safety Standards.

DATE: 1 / 20 / 15

OWNER / CONTRACTOR: APOPEI

PERMIT NUMBER: ESF14-05641

ADDRESS: 5555 116TH AVE NE.

☐ NOT APPROVED FOR COVER ☐ NOT APPROVED FOR SERVICE

SAFETY DEFECTS NEEDING CORRECTION

1. SMOKE & CO ALARMS REQUIRE INTERLOCK WITH REMAINDER OF HOUSE

2. ∅ REQUIRED UNDER HOUSE FOR HVAC SERVICE

NOTIFY INSPECTION OFFICE WHEN READY FOR REINSPECTION

MIKE MCGIVERN
INSPECTOR

Page 1 of 1