

BULLETIN

Date: March 20, 2015	Number: CT-01	Project #: 14173
Project Name: Kirkland Townhomes		Attached: n/a

Subject: Special Inspection - Footings

Drawings Affected: n/a

Description/Action:

This bulletin provides design clarifications and/or variation requests for the 'Kirkland Townhomes' project located in Kirkland, Washington.

We understand that there was no special inspection for the footings that were installed and the concrete that was placed on February 23, 2015. We also understand that the footings were reviewed by the City Inspector prior to the placement of the concrete. The plans call for special inspection which also involves making cylinders of the concrete during placement for strength verification.

We have reviewed the design mix and the historical data regarding previous cylinder breaks for the mix in question. It is our opinion that the footing mix used is adequate and that no destructive testing is required to verify the concrete strength. We recommend that a Special Inspector be engaged to verify the footing size and location of the dowels and provide a report with this information noted. We understand that the remaining concrete pours will have special inspection as required in the Structural Notes.

We trust that this will allow you to proceed with construction of the remaining concrete walls and footings. Please call or email if you have any questions.



03/20/2015

CALL WITH ANY QUESTIONS

Issued by: <u>Craig Roberts, SE</u>	Date: <u>March 20, 2015</u>
Distribution: _____	
Contact Information:	
<u>Karl Crabs</u>	
<u>Nebil Dikmen</u>	

