

ELECTRICAL PERMIT * E12-14415

Job Address: **6100 CARILLON PT , 1ST 100**

APPLICANT
 Brandon Vincent (425) 454-3665
 18133 NE 68th St
 D120



FINALED 5-14-12

MyBuildingPermit.com

Work Type: **ALTERATION**
 Use Type: **COMMERCIAL**

Proj./Tenant: **CARILLON PROPERTIES**
 Related Prmt #: **W/COM/ELE**

Area of Work:
 Fair Market Value: **\$8,475.00**

CONTRACTOR - ELECTRICAL
 PRIDE ELECTRIC
 (425) 454-3665

OWNER
 * CARILLON PROPERTIES W BLVD

Job Notes:
 (1 Primary Building, 1 Installation of equipment, 1 Dishwasher - circuit, 1 Garbage Disposal - circuit, 1 Hot Water Tank - circuit, 1 HVAC Equipment - Inside, 5 Light Fixture - circuit, 6 Office Furniture, 12 Receptacle - circuit, 4 Switch - circuit)

TOTAL FEES: \$ 295.29
COUNT OF FEES: 2

Type	Amount	By	Date	Receipt #
ELE	\$291.50	MBP	3/28/2012	
TECH	\$3.79	MBP	3/28/2012	

Number of New or Altered Branch Circuits:

Type of Electrical Use:

To Serve These Appliances

Air Conditioner:	Garbage Disposal:	1.00
Clothes Dryer:	Hood Fan:	
Clothes Washer:	Small Appliance Circuit:	
Dish Washer:	Range / Oven:	
Elec. HW Tank:	Space Heater:	

NEW

Light Fixtures:	5.00
Switches:	4.00
Receptacles (outlets):	12.00

LOW VOLTAGE

Limited/Low Voltage:
 Linear Feet:

Electrical Permit Conditions:

- Do not cover any work until an inspection has been approved.
- Electrical ground rods: When two rod or pipe electrodes are installed vertically they shall be installed not less than six feet (6') apart and a minimum of eight (8') feet in length and 5/8 diameter.
- GFCI protection is required for all 15 and 20 amp receptacles installed outside of a building, or within six feet (6') of a sink (or other fixed water source), or in areas used or intended to be used under wet or damp conditions.

	Date	Inspector
WALL CVR Temp. Power	4/8/2012	PXA
Underslab		
Service CEILING Rough In	5/1/2012	PXA
Final	5/14/2012	PXA

Low Voltage Inspections		
	Date	Inspector
Underslab		
Rough In		
Final		

Notes:

See Reverse Side for Additional Notes

