

ELECTRICAL PERMIT * E12-12673

Job Address: **4205 CARILLON PT , 2ND FLOOR 4205**

APPLICANT
 Dave Hampton (425) 778-7916
 1729 181st Pl SW
 Lynnwood, WA 98037



Work Type: **ALTERATION**
 Use Type: **COMMERCIAL**

Proj./Tenant: **CARILLON PROP/COMM/ELE**
 Related Prmt #:

Area of Work:
 Fair Market Value: **\$5,500.00**

CONTRACTOR - ELECTRICAL
 HAMPTON ELECTRIC INC
 (425) 778-7916

OWNER
 * CARILLON PROPERTIES W BLVD

Job Notes:
 (1 Primary Building, 16 Adding or Altering Branch Circuits,
 1 HVAC Equipment - Inside, 16 Receptacle - circuit, 3
 Switch - circuit)

TOTAL FEES: \$ 245.15
COUNT OF FEES: 2

Type	Amount	By	Date	Receipt #
ELE	\$242.00	MBP	2/9/2012	
TECH	\$3.15	MBP	2/9/2012	

Number of New or Altered Branch Circuits:

Type of Electrical Use:

To Serve These Appliances

Air Conditioner:	Garbage Disposal:
Clothes Dryer:	Hood Fan:
Clothes Washer:	Small Appliance Circuit:
Dish Washer:	Range / Oven:
Elec. HW Tank:	Space Heater:

NEW

Light Fixtures:	
Switches:	3.00
Receptacles (outlets):	16.00

LOW VOLTAGE

Limited/Low Voltage:	
Linear Feet:	

Electrical Permit Conditions:

- Do not cover any work until an inspection has been approved.
- Electrical ground rods: When two rod or pipe electrodes are installed vertically they shall be installed not less than six feet (6') apart and a minimum of eight (8') feet in length and 5/8 diameter.
- GFCI protection is required for all 15 and 20 amp receptacles installed outside of a building, or within six feet (6') of a sink (or other fixed water source), or in areas used or intended to be used under wet or damp conditions.

	Date	Inspector
WALL CVR Temp. Power	2/10/2012	PXA
Underslab		
Service CEILING CVR	2/21/2012	PXA
Rough In	2/17/2012	PXA
Final		

Low Voltage Inspections

	Date	Inspector
Underslab		
Rough In		
Final		

Notes: 2/16/2012 PARTIAL CEILING CVR PXA

See Reverse Side for Additional Notes

