ELECTRICAL PERMIT * **E12-14416**

Job Address: **6100 CARILLON PT , 2ND FLOOR SUITE 200**

APPLICANT
Brandon Vincent (425) 454-3665
18133 NE 68th St
D120

FINALED 5-14-12

MyBuildingPermit.com

Work Type: **ALTERATION**
Use Type: **COMMERCIAL**

Proj./Tenant: **CARILLON PROPERTIES**
Related Prmt #: **W/COM/ELE**

Area of Work:
Fair Market Value: **$21,700.00**

CONTRACTOR - ELECTRICAL
PRIDE ELECTRIC
(425) 454-3665

OWNER
* CARILLON PROPERTIES W BLVD

Job Notes:
(1 Primary Building, 1 Installation of equipment, 1 Dishwasher - circuit, 1 Garbage Disposal - circuit, 1 Hot Water Tank - circuit, 1 HVAC Equipment - Inside, 22 Light Fixture - circuit, 27 Receptacle - circuit, 11 Switch - circuit)

TOTAL FEES: $ 512.58
COUNT OF FEES: 2

Type	Amount	By	Date	Receipt #
ELE	$506.00	MBP	3/28/2012	
TECH	$6.58	MBP	3/28/2012	

Number of New or Altered Branch Circuits:

To Serve These Appliances

Air Conditioner:		Garbage Disposal:	1.00
Clothes Dryer:		Hood Fan:	
Clothes Washer:		Small Appliance Circuit:	
Dish Washer:	1.00	Range / Oven:	
Elec. HW Tank:	1.00	Space Heater:	

Type of Electrical Use:

NEW

Light Fixtures:	22.00
Switches:	11.00
Receptacles (outlets):	27.00

LOW VOLTAGE

Limited/Low Voltage:
Linear Feet:

Electrical Permit Conditions:
1. Do not cover any work until an inspection has been approved.
2. Electrical ground rods: When two rod or pipe electrodes are installed vertically they shall be installed not less than six feet (6') apart and a minimum of eight (8') feet in length and 5/8 diameter.
3. GFCI protection is required for all 15 and 20 amp receptacles installed outside of a building, or within six feet (6') of a sink (or other fixed water source), or in areas used or intended to be used under wet or damp conditions.

	Date	Inspector
WALL CVR ~~Temp. Power~~	4/16/2012	PXA
Underslab		
Service		
CEILING CVR Rough In	5/1/2012	PXA
Final	5/14/2012	PXA

Low Voltage Inspections

	Date	Inspector
Underslab		
Rough In		
Final		

Notes:

See Reverse Side for Additional Notes

Application Date: **3/28/2012** Expiration Date: **3/28/2013** Issued Date: **3/28/2012**

CONCRETE Footings - Setback	by	**PLUMBING**		**MECHANICAL** Rough In	by
		Groundwork / Hyd Heat	by	mech final	by
Foundation Walls	by	D.W.V.	by	gas piping	by
		Water Line	by	refr piping	by
S.O.G. Insulation	by	Service Line	by	**SUSPENDED CEILING**	
SHEATHING		**INSULATION**		date	by
ext walls	by	floors	by	**WALLBOARD NAILING**	
roof	by	walls	by	date	by
floor	by	attic	by	**FINAL INSPECTION**	
FRAMING		Membrane / Flashing	by	date 5/14/2012	by PXA
date	by	Ext Lath / Gyp Sheathing	by	**FIRE DEPT.**	by
Sub-Floor framing date	by	Footing / Stm Drains	by	fire stop / caulking	by