

LV ELECTRICAL PERMIT * E12-14228

Job Address: **6100 CARILLON PT , 1 AMP 2 NONE**

APPLICANT
Interface Technologies Northwest Inc 253-774-1377 2408
4425 164th St. SW
Lynnwood, WA 98087



FINALED 5-14-12

MyBuildingPermit.com
a service of eCityDesk.net

Work Type: **ALTERATION**
Use Type: **COMMERCIAL**

Proj./Tenant: **SOUTHERN WINE &**
Related Prmt #: **SPIRITS/COMM/LV**

Area of Work:
Fair Market Value: **\$19,903.00**

CONTRACTOR
INTERFACE TECHNOLOGIES NORTHWEST IN
(425) 774-1377 2408

OWNER
* CARILLON PROPERTIES W BLVD

Job Notes:
(1 Primary Building, 1 Low Voltage data cable system -
Not SF)

TOTAL FEES: \$ 119.79
COUNT OF FEES: 2

Type	Amount	By	Date	Receipt #
ELE	\$118.25	MBP	3/23/2012	
TECH	\$1.54	MBP	3/23/2012	

Number of New or Altered Branch Circuits:

Type of Electrical Use:

To Serve These Appliances

Air Conditioner:	Garbage Disposal:
Clothes Dryer:	Hood Fan:
Clothes Washer:	Small Appliance Circuit:
Dish Washer:	Range / Oven:
Elec. HW Tank:	Space Heater:

NEW

Light Fixtures:
Switches:
Receptacles (outlets):

LOW VOLTAGE

Limited/Low Voltage:
Linear Feet:

Electrical Permit Conditions:

- Do not cover any work until an inspection has been approved.
- Electrical ground rods: When two rod or pipe electrodes are installed vertically they shall be installed not less than six feet (6') apart and a minimum of eight (8') feet in length and 5/8 diameter.
- GFCI protection is required for all 15 and 20 amp receptacles installed outside of a building, or within six feet (6') of a sink (or other fixed water source), or in areas used or intended to be used under wet or damp conditions.

	Date	Inspector
Temp. Power	_____	_____
Underslab	_____	_____
Service	_____	_____
Rough In	_____	_____
Final	_____	_____

	<u>Low Voltage Inspections</u>	
	Date	Inspector
Underslab	4/26/2012	PXA
Rough In	5/14/2012	PXA
Final		

Notes:

See Reverse Side for Additional Notes

