

**ELECTRICAL PERMIT \* E12-12464**

Job Address: **2300 CARILLON PT , 3RD FLOOR 3200**

**APPLICANT**  
 Dirk Johnson (425) 334-1955  
 3326 Bickford Avenue  
 Po Box 280



Work Type: **ALTERATION**  
 Use Type: **COMMERCIAL**

Proj./Tenant: **PENDRELL/COMM FL3**  
 Related Prmt #: **STE3000/ELE**

Area of Work:  
 Fair Market Value: **\$6,500.00**

**CONTRACTOR - ELECTRICAL**  
 ASSOCIATED ELECTRIC COMPANY  
 (425) 334-1955

**OWNER**  
 \* CARILLON PROPERTIES W BLVD

Job Notes:  
 (1 Primary Building, 8 Adding or Altering Branch Circuits,  
 6 Switch - circuit)

**TOTAL FEES: \$ 261.86**  
**COUNT OF FEES: 2**

Type	Amount	By	Date	Receipt #
ELE	\$258.50	MBP	2/3/2012	
TECH	\$3.36	MBP	2/3/2012	

Number of New or Altered Branch Circuits:

Type of Electrical Use:

To Serve These Appliances

Air Conditioner: Garbage Disposal:  
 Clothes Dryer: Hood Fan:  
 Clothes Washer: Small Appliance Circuit:  
 Dish Washer: Range / Oven:  
 Elec. HW Tank: Space Heater:

NEW

Light Fixtures:  
 Switches: **6.00**  
 Receptacles (outlets):

LOW VOLTAGE

Limited/Low Voltage:  
 Linear Feet:

**Electrical Permit Conditions:**

- Do not cover any work until an inspection has been approved.
- Electrical ground rods: When two rod or pipe electrodes are installed vertically they shall be installed not less than six feet (6') apart and a minimum of eight (8') feet in length and 5/8 diameter.
- GFCI protection is required for all 15 and 20 amp receptacles installed outside of a building, or within six feet (6') of a sink (or other fixed water source), or in areas used or intended to be used under wet or damp conditions.

	Date	Inspector
Temp. Power		
Underslab	WAZL CVC 3/8/12	JKH
Service		
Rough In	LEI LWB CVC 4/2/12	PKA
Final	4/30/2012	PKA

<u>Low Voltage Inspections</u>		
	Date	Inspector
Underslab		
Rough In		
Final		

Notes:

See Reverse Side for Additional Notes

Application Date: 2/3/2012

Expiration Date: 2/3/2013

Issued Date: 2/3/2012

