# Mechanical Permit

City of Kirkland
123 Fifth Avenue
Kirkland WA 98033
425-587-3600

Permit Number: MNR12-01055
IVR Permit PIN Number: 100841
Type: Mechanical Non Residential - MNR
Work Class: Alteration to Structure or System

MNR12-01055

## Permit Information

| | | | |
|---|---|---|---|
| **Job Address:** | **Project:** | **Application Date:** | 05/15/2012 |
| 4100 CARILLON PT<br>Kirkland, WA 98033 | **Parcel:** 1725059058 | **Issue Date:** | 05/22/2012 |
| | **Valuation:** $ 3,633.00 | **Expiration Date:** | 05/22/2013 |
| | **Dwelling Units:** | **Code Edition:** | |

## Scope of Work

Non-Residential - 4th Floor/Building #6 - Install new VAV box for NW corner office, disconnect NW corner office from existing VAV box, and install duct work from new VAV box to existing supply diffuser.

## Contacts

| Type | Name | Address | Phone |
|---|---|---|---|
| Applicant | MBP CONTACT IMPORT<br>MBP CONTACT | 123 5TH AVE<br>3885808355, WA 98033 | B:<br>C: |
| Contractor | PSR-HVAC & MECHANICAL SERVICES | PO BOX 27073<br>SEATTLE, WA 98165 | B: 206-367-2500<br>C: |
| Primary Contact | PAUL GOTO<br>PSR MECHANICAL | 3132 NE 133RD ST<br>SEATTLE, WA 98165 | B: 206-367-2500<br>C: |

**Request an inspection before 3 p.m. for next business day. Requests made after 3 p.m. will be scheduled on the second business day following the request.**

**How to request an inspection:**
1) Dial **1-866-458-7354**.
2) From the main menu, enter your 6 digit IVR number (100841).
3) Next, the system will ask you to confirm your permit number (MNR12-01055). Press 1 to confirm the correct permit number.
4) Select option 3 to request a new inspection. From there enter the 3 digit inspection pin number, from the inspections to the right, for the inspection that you are requesting.

## REQUIRED INSPECTIONS

| Inspection | IVR | Date | Insp |
|---|---|---|---|
| 1. MEC - Other | 301 | | |
| 2. MEC - Fuel Gas Piping | 310 | | |
| 3. MEC - Hydronic Tubing | 316 | | |
| 4. MEC - Wall Cover | 316 | | |
| 5. MEC - HVAC Piping (Hydronic/Chilled/Refrigerant) | 318 | | |
| 6. MEC - Rough Mechanical | 320 | 6/22/12 | PXA |
| 7. MEC - Fire/Smoke Dampers | 340 | | |
| 8. MEC - Ceiling Cover | 340 | 6/22/12 | PXA |
| 9. MEC - Duct Seal | 341 | 6/22/12 | PXA |
| 10. MEC - Duct Insulation | 342 | | |
| 11. MEC - Final | 395 | 6/22/12 | PXA |

FINALED 6-22-12

## Signature

**See conditions on the back of this permit.**
This permit and any accompanying plans must remain on the job site for use by City inspection personnel.
Any sales tax reported to the State in association with this project should be coded to the City of Kirkland tax location code 1716.
I certify that the information furnished by me is true and correct to the best of my knowledge and the applicable City of Kirkland requirements will be met.

☐ Owner or ☐ Agent (Check one)

_____ (Print Name)

DATE: _____

_____ (Signature)

City of Kirkland
123 Fifth Avenue
Kirkland WA 98033
425-587-3600

Permit Number: MNR12-01055
IVR Permit PIN Number: 100841
Type: Mechanical Non Residential - MNR
Work Class: Alteration to Structure or System

## General Conditions

1. The issuance of this permit shall not be construed to be a permit for, or an approval of, any violation of any of the provisions of this code or of any other ordinances of the jurisdiction.
2. The approved plans shall not be changed, modified, or altered without authorization from the building official.
3. This permit, inspection record and approved plans are required to be on the job site at all times.
4. All development activity and heavy equipment operation is restricted to 7:00 a.m. to 8:00 p.m., Monday through Friday, and 9:00 a.m. to 6:00 on Saturdays. No development activity or heavy equipment operation may occur on Sundays or holidays observed by the City.
5. All work is subject to field inspection. Do not cover any work until approved by a City inspector.
6. Inspection(s) required - call 1-866-458-7354 (24 hours a day) no later than 3:00 pm the day before the inspection is desired. (Follow the IVR instructions on the front of this sheet).

## Inspector's Comments

City of Kirkland
123 5th Avenue
Kirkland, WA 98033
425-587-3600

# SPECIFIC PERMIT CONDITIONS

| BUILDING ADDRESS | PERMIT NO. | IVR PERMIT PIN # | PERMIT TYPE | WORKCLASS | DATE PRINTED |
|---|---|---|---|---|---|
| 4100 CARILLON PT | MNR12-01055 | 100841 | Mechanical Non Residential - MNR | Alteration to Structure or System | 5/22/2012 |

DESCRIPTION OF WORK:
Non-Residential - 4th Floor/Building #6 - Install new VAV box for NW corner office, disconnect NW corner office from existing VAV box, and install duct work from new VAV box

**Building Department Conditions:**

All work is subject to field inspection.

Separate Electrical Permit and inspection is required.
Do not cover any repaired or replaced areas prior to Building division inspection and approval.

Electrical Installation. Appliances shall be installed per National Electrical Code. (NEC) and WA. State Cities Electric Code.

Seismic resistance. When earthquake loads are applicable in accordance with the International Building Code, mechanical system supports shall be designed and installed for the seismic forces in accordance with the International Building Code. IMC

Installation Instructions: Equipment and appliances shall be installed as required by the terms of their approval, in accordance with the conditions of the listing, the manufacturer's installation instructions and this code. Manufacturer's installation instructions shall be available on the job site at the time of inspection. IMC