



Fire Application #262481 - Kirkland Parkplace Lobby

Project Contact

Company Name: McKinstry Co

Name: Jim Thomas **Email:** permits@mckinstry.com

Address: 5005 3rd Ave S PO Box 24567 **Phone #:** (206) 763-4819
Seattle WA 98134

Project Type	Activity Type	Scope of Work
Nonresidential	Alteration	Fire Sprinkler Systems

Project Name: Kirkland Parkplace Lobby

Description of Work: Upgrade current system in designated area to quick response upright and pendant sprinklers. Add 14 and relocate 19 upright and pendant sprinklers at the Kirkland Parkplace Marketing Suite in order to accommodate tenant improvements.

Project Details

System Information

This is a modification or addition to an existing system

Fire System Type

NFPA 13

Alterations

There are no alterations to devices or systems.

Quick Response or Recalled Head Change Out

The K-Factor and spacing match existing.

Quick Response or Recalled Head Relocation

Heads are being relocated.

Change of Use

This is not a change of use.

Hydraulic Calculations

There is no change to the hydraulic calculations.

Hazard Classification

The space is classified as Light/Ordinary Hazard.

Mains and Cross Mains

Mains or cross mains are not being relocated.

Heads - Excluding Quick Response and Recalled

26 - 100 total heads

Fire System Counts

Number of Heads Added	14
Number of Heads Capped or plugged	2
Number of Heads Relocated	19
Number of Quick Response Heads	18
Number of Total Heads	35

Additional Project Information

The work includes quick response or recalled heads.



CITY OF KIRKLAND



Fire Application #262481 - Kirkland Parkplace Lobby