

Field Report

Report #: 62786

A.A.R. Testing Laboratory, Inc. 7126 180th Ave.N.E., Park 180, Suite C101, Redmond, WA 98052
Phone 425.881.5812 Fax 425.881.5441

Client: DGR Development, Inc.
7931 233rd Place S.E.
Woodinville, WA 98072

Project Number: 15-347
Permit #: BNR 15-00957
Project Name: Alexa Lane
Address: 12643 N.E. 70th St.

Contact: Michael Roland

Inspection Performed: Resteel

Date: 7/7/2015

Time:

Temperature:

On site to inspect the reinforcement for the vault lid. Verified reinforcement size, grade, spacing, lap splice and clearances. Reinforcement was per plans and specifications.

Distribution:

- | | |
|---|---|
| <input checked="" type="checkbox"/> Distribute Client | <input checked="" type="checkbox"/> Distribute Contractor |
| <input type="checkbox"/> Distribute Engineer | <input type="checkbox"/> Distribute Owner |
| <input checked="" type="checkbox"/> Distribute Municipality | <input type="checkbox"/> Distribute Other |
| <input type="checkbox"/> Distribute Architect | <input type="checkbox"/> Distribute Other |

Inspector: Horton, Tim

Reviewed by: Michele Guerrini

All reports are considered confidential and are the property of the client and A.A.R. Testing Laboratory, Inc. Reproduction except in full without the written consent of A.A.R. Testing is strictly forbidden