CITY OF KIRKLAND
123 5th Avenue
Kirkland, WA 98033
www.kirklandpermits.net

DO NOT REMOVE

BUILDING INSPECTION CORRECTION REPORT

☐ The corrections must be completed within 15 days.

	DATE 9/10/15
TYPE OF INSPECTION ROUGH	PERMIT NUMBER BSF14-05361
ADDRESS 12228 90TH AVE NE	

☐ BUILDING ☐ PLUMBING ☑ MECHANICAL ☑ ELECTRICAL ☐ OTHER

(1) LOW VOLTAGE AT EXT. WALLS REQUIRES BOX CAPABLE OF AIR SEALING

(2) INSTALL MUDRING FOR GAS PIPE BOND

(3) GARAGE CIRCUIT SHALL NOT SUPPLY ⦶s NOT IN GARAGE (FRONT OUTSIDE) 2014 NEC 210.52 (G)(1)

(4) NO SMOKE/CO ON LOWER LEVEL

(5) ⦶ NOT WITHIN 6' OF CLOSET MID LEVEL SOUTH WINDOW WALL

MECHANICAL

(1) AS PER CORRECTION DATED 8/17/15 OUTSIDE AIR DUCT IS NOT INSULATED

INSPECTOR MIKE MCGIVERN

When ready for reinspection, call 1-866-458-7354 or online at mybuildingpermit.com prior to 3 p.m. for next day inspection.
Building Department Business Line: (425) 587-3600.