



CITY OF KIRKLAND
 123 5th Avenue
 Kirkland, WA 98033
 www.kirklandpermits.net

DO NOT REMOVE BUILDING INSPECTION CORRECTION REPORT

The corrections must be completed within 15 days.

DATE 4/20/16
PERMIT NUMBER ESF16-02897

TYPE OF INSPECTION TEMP
ADDRESS 12618/12626 NE 105 PL

BUILDING PLUMBING MECHANICAL ELECTRICAL OTHER

(1) NEEDS K-O SEAL @ BOTTOM HOLES.

(2) COVER FALLS OFF.

INSPECTOR TD

When ready for reinspection, call 1-866-458-7354 or online at mybuildingpermit.com prior to 3 p.m. for next day inspection.
 Building Department Business Line: (425) 587-3600.