



CITY OF KIRKLAND
 123 5th Avenue
 Kirkland, WA 98033
 www.kirklandpermits.net

DO NOT REMOVE BUILDING INSPECTION CORRECTION REPORT

The corrections must be completed within 15 days.

DATE
 6 / 14 / 16

TYPE OF INSPECTION
 FRAMING

PERMIT NUMBER
 B3F15-03149

ADDRESS
 7804 123RD AVE NE

BUILDING PLUMBING MECHANICAL ELECTRICAL OTHER

① ROUGH MECHANICAL IS REQUIRED TO BE APPROVED PRIOR TO FRAMING. ROUGH MECHANICAL HAS NOT BEEN REQUESTED AND IS NOT APPROVED BECAUSE DUCTS ARE NOT ALLOWED IN EXTERIOR WALLS BECAUSE INSULATION IS DISPLACED. WA. STATE ENERGY CODE.

NO FRAMING INSPECTION UNTIL ROUGH MECHANICAL IS APPROVED.

INSPECTOR MIKE MCBIVERN

When ready for reinspection, you may request one online at <https://inspection.mybuildingpermit.com> or by calling 1-866-458-7354 prior to 3:00 p.m. for next day inspection.
 Planning and Building Department business line: (425) 587-3600.