



CITY OF KIRKLAND
 123 5th Avenue
 Kirkland, WA 98033
www.kirklandpermits.net

DO NOT REMOVE BUILDING INSPECTION CORRECTION REPORT

The corrections must be completed within 15 days.

DATE	7 120 1 16
PERMIT NUMBER	BSF 15-04903

TYPE OF INSPECTION	ELECTRICAL FINAL
ADDRESS	2800 NE 117th PL

BUILDING PLUMBING MECHANICAL ELECTRICAL OTHER

JACUZZI RECEPTACLE HAS HOT
 AND NEUTRAL REVERSED.

INSPECTOR

RC

When ready for reinspection, you may request one online at <https://inspection.mybuildingpermit.com> or by calling 1-866-458-7354 prior to 3:00 p.m. for next day inspection.

Planning and Building Department business line: (425) 587-3600.